Problem:

In the Win 7 or Vista OS, error message "Run-time error xx" .ocx file is not correctly registered as below picture:



Solution:

Step 1. Re-Install and run DCON Utility as administrator :

Please uninstall DCON Utility and reboot OS .Then install it as administrator. When you want to use DCON Utility, please run it as

administrator. And it will work correctly.



- Step 2. Backup all *.ocx files and REGSVR32.EXE on the system32 catalog:
 Please backup all .ocx files and REGSVR32.EXE that located at
 c:\windows\system32\ catalog on your PC
- Step 3. Replace all file that located at DCON_Utility\ocx_file\ to system32 : Please copy all files (*.OCX ,REGSVR32.EXE and REGISTER.BAT) that located at DCON_Utility\ocx_file\ to your system32 catalog (they are located at : C:\WINDOWS\system32\), then run the REGISTER.BAT as administrator to register all ocx files . Run DCON Utility as administrator, it will work correctly.
- Step 4. After replace files to your PC. If System has any problems, please use Step 2 files to return it.

If it still has any problems, please mail to us. Service@icpdas.com