

分類/Classification	<input type="checkbox"/> tDS	<input type="checkbox"/> tGW	<input type="checkbox"/> PETL/tET/tPET	<input type="checkbox"/> DS/PDS/PPDS	<input checked="" type="checkbox"/> TouchPAD
作者/Author	<input type="checkbox"/> I/O Card	<input type="checkbox"/> VXC Card	<input type="checkbox"/> VxComm	<input type="checkbox"/> Other	
日期/Date		編號/NO.	FAQ001		

## Q: How many TouchPAD devices can be put in a RS-485 network?

A: Due to impedance matching, about 16 TouchPAD devices can be put in the same RS-485 network. If more TouchPAD devices than 16 are required, use a RS-485 repeater I-7510 to bridge them.

For more information about I-7510, refer

to [http://www.icpdas.com/root/product/solutions/industrial\\_communication/converter/i-7510.html](http://www.icpdas.com/root/product/solutions/industrial_communication/converter/i-7510.html)