



<b>□</b> Features
■ 1 x stepper motor (2-phase bipolar stepper motor)
■ Drive capability up to 1.5A coil current (with proper cooling and airflow up to 2.0A)
■ Voltage range of the motor: 5 to 46 VDC
■ 1 x 5V power supply for encoder. Limitation: the output current should not exceed 150mA
■ 1 x Encoder interfaces (A, B, Z), differential
■ 2x Digital input: Reference switch input, latch input
■ 1 x Digital output
■ Highest resolution: 256 microsteps per full step
Automatic current reduction to reduce heat when motor is not moving
Over-temperature protection
Optically isolated I/O
■ LED indicators for I/O, EtherCAT and motion status
EtherCAT:
☐ 2 x RJ-45 bus interface
☐ Distance between stations up to 100 m (100BASE-TX)
☐ Support daisy chain connection
☐ EtherCAT conformance test tool verified
<ul> <li>Supports Free-Run, SM synchron and Distributed Clock (DC) operation modes</li> </ul>
Removable terminal block connector
CE FE KOH

#### ✓ Introduction \_

The ECAT-2091S stepper motor controller is a cost-effective, two-phase bipolar stepper driver. A motor voltage range between 5 and 46 VDC and a peak motor coil current of 1.5A without cooling is being supported. When operating in a properly ventilated environment (cooling fan) the ECAT-2091S can drive the motor at a current level of up to 2.0A. The maximum running motor current, microstep resolution and other motion parameters are software selectable.

The ECAT-2091S is a standard EtherCAT slave and an EtherCAT master is required to operate the device. The ECAT-2091S supports three operation modes: Free-Run, SM synchron and Distributed Clock (DC).

Two-phase bipolar stepper motors can be directly connected to the ECAT-2091S device. The device is designed to operate in a open loop. Configuration and motion control has to be done by the EtherCAT master and the application program. The coil current and step control done by a stepper motor driver IC. An integrated ramp generator automatically calculates the acceleration and deceleration distance. In position mode the controller drives the motor to the target position and in velocity mode accelerates the motor to the target velocity. A minimum set of configuration data consists of acceleration, deceleration and maximum motion velocity. After receiving the target position the motor driver starts controlling the motion movement. All motion parameters can be changed on the fly.

The ECAT-2091S has a 32 bit high frequency encoder counter which counts the input signal of an external incremental encoder. The encoder can for example be used for homing purposes and for consistency checks.

High resolution of up to 256 microsteps per full step is supported for a ensuring smooth and precise motor operation.

Two digital input channels are provided. The digital inputs can be set to act as a simple DI, as a left and right hardware limit switch which automatically stops the motor when activated, or a latch trigger for latching the current motor and encoder position.

The module must be supplied by two power sources. A motor supply and a 24 VDC control supply.

# ☑ Hardware Specifications \_\_\_\_\_\_\_

Model		Specification	
Motor outputs			
Number of Outputs		1 × stepper motor, 2 phases	
Output Current		peak 1.5 A (with proper airflow up to 2.0A)	
Voltage Range of	the Motor Output	5 to 46 VDC	
Current Controller	Frequency	24.5 kHz	
Maximum Step Fro	equency	8.388 MHz	
Microsteps per ste		256, 128, 64, 32, 16, 8, 4, 2	
Encoder	·		
Number of Encode	er Inputs	$1 \times$ encoder counter (A, B, Z), differential	
Maximum Encode	r Pulse Frequency	4 MHz	
Power supply		5V (Restriction: the output current should not exceed 150 mA)	
Digital Inputs			
Number of Digital	Inputs	2	
	ON Voltage Level	+19 to 30 VDC	
Wet contact	OFF Voltage Level	+11 VDC MAX	
Photo-Isolation	-	3750 VDC	
Digital Output			
Number of Digital	Outputs	1	
Output Type		Open collector	
Load Voltage		+5 to 30 VDC	
Max. Load Curren	t	100 mA	
Isolation Voltage		3750 VDC	
LED Indicators			
Diagnostic LED		Power, EtherCAT status, Digital IO, driving, temperature warning, over-temperature error, phase A and B under-voltage	
Communication	Interface	priase A una b unaer voltage	
Connector		2 × RJ-45	
Protocol		EtherCAT	
Distance Between	Stations	Max. 100 m (100BASE-TX)	
Data Transfer Med	dium	Ethernet/EtherCAT Cable (Min. CAT 5), Shielded	
Power			
Input Voltage Ran	ige	20 V ~ 30 VDC	
<b>EMS Protection</b>			
ESD (IEC 61000-4	l-2)	4 KV Contact for each channel	
EFT (IEC 61000-4	-4)	Signal: 1 KV Class A; Power: 1 KV Class A	
Surge (IEC 61000	-4-5)	1 KV Class A	
Mechanism			
Installation		DIN-Rail	
Dimensions (L × W × H) [mm]		110 mm $\times$ 90 mm $\times$ 33 mm (without connectors)	
Case Material		Metal	
Environment			
Operating Temperature		-25 ∼ +40°C	
Storage Temperature		-30 ~ +80°C	
Relative Humidity		10 ~ 90% RH, Non-condensing	
Relative Humidity		10 ~ 3070 KH, NOH-CONDENSING	

Table 1: Technical data

E-mail: sales@icpdas.com



# ☑ Dimensions (Units: mm) \_




Figure 1: Dimensions of the ECAT-2091S

### ☑ Pin Assignments \_



Name	Signal	
F.G	Frame ground	
GND	Power supply: Ground 0V (from negative power contact)	
+Vs	Power supply: +24 VDC (from positive power contact)	
IN	EtherCAT signal input	
OUT	EtherCAT signal input	

Table 2: ECAT-2091S power supply and EtherCAT interfaces

Figure 2: ECAT-2091S side view with power supply and EtherCAT connection

Name	Signal	Signal Description
OA1	Output	Motor winding A1
OA2	Output	Motor winding A2
OB1	Output	Motor winding B1
OB2	Output	Motor winding B2
LL	Input	Right limit switch for motor
RL	Input	Left limit switch for motor
GDO0	Output	General purpose digital output channel 0
DI.COM		Common DI supply: 0V or +10 to +24 VDC (0V for current sinking)
+VS		+24 VDC
GND		Ground 0V

Table 3: Connection interfaces for the motor current outputs, digital inputs and output

EC	AT-209	
RI	IN IN OU	T ty
	2 3 4 5	
8 9	10 11 12 13	1415
		enime)
OA1 OA2 OB1 OB2 RL LL GD00 DL00M +V6 GND		2 A+ A- B+ B- C+ C- +5V +VM 4VE GNO


Name	Signal	Signal Description
A+	Input	Encoder input A+
A-	Input	Encoder input A-
B+	Input	Encoder input B+
B-	Input	Encoder input B-
C+	Input	Encoder input C+
C-	Input	Encoder input C-
+5V	Output	Power supply to encoder Limitation: • The output current should not exceed 150mA • Only one encoder should be connected
+VM	Input	Motor power supply +5 to 46 VDC (from positive power contact)
+VS		+24 VDC
GND		Ground 0V


Table 4: Connection interfaces for the encoder and motor power supply

Figure 3: ECAT-2091S front view with motor and encoder in- and outputs



Figure 4: ECAT-2091S connected to a stepper motor








Figure 5: Four lead bipolar motor connection

Figure 6: Eight lead bipolar motor connection (left: series, right: parallel)




Figure 7: Differential encoder connection




# ☑ Digital Input Channel

## Digital Input Channel

Digital Input	Readback as 1	Readback as 0
	+10 ~ +24 VDC	OPEN or <4 VDC
Sink	RL/LL 3K  + -  DI.COM	RL/LL 3K
	+10 ~ +24 VDC	OPEN or <4 VDC
Source	RL/LL 3K  DI.COM	RL/LL 3K  - +  DI.COM

Figure 9: Digital inputs RL and LL

## Digital Output Channel



Output Type	ON State Readback as 1	OFF State Readback as 0
Drive Relay	+Vs GDO 0 GND	+Vs GDO 0 GND
Resistance Load	+Vs GDO 0 GND	+Vs GDO 0 GND

Figure 10: General purpose DO block diagram Figure 11: General purpose DO channel 0

### **☑** Application Example .



## **☑** Ordering Information .

ECAT-2091S CR

EtherCAT single axis stepper motor controller/ driver (RoHS)