

Linux M-7000

Linux M-7000 User Manual

Warranty

All products manufactured by ICP DAS are warranted against defective materials for a period of one year from the date of delivery to the original purchaser.

Warning

ICP DAS assume no liability for damages consequent to the use of this product. ICP DAS reserves the right to change this manual at any time without notice. The information furnished by ICP DAS is believed to be accurate and reliable. However, no responsibility is assumed by ICP DAS for its use, nor for any infringements of patents or other rights of third parties resulting from its use.

Copyright

Copyright 2015 by ICP DAS. All rights are reserved.

Trademark

The names used for identification only may be registered trademarks of their respective companies.

Tables of Content

目錄

1.	M-7000 lib compile & default setting.....	4
1.1	M-7000 lib compile	4
1.2	M-7000 default setting.....	4
2.	M-7000 Serial static Library Function Description.....	5
2.1	Table of ErrorCode and ErrorString.....	6
2.2	System Functions	7
2.2.1	Open_Com	7
2.2.2	modbusRequest	7
2.2.3	Close_Com.....	8
3.	M-7000 series Demo Program For Linux	9
3.1	Demo Modbus_utility	11
3.2	Demo setmodebus.....	11
3.3	Demo getmodbus.....	11
3.4	Demo do	12
3.5	Demo multi_do.....	12
3.6	Demo do_readback.....	12
3.7	Demo di.....	13
3.8	Demo di_counter	13
3.9	Demo firmware_ver	13
3.10	Demo module_name	14
3.11	Demo set_mod_add.....	14
3.12	Demo set_comm_set	14
3.13	Demo read_comm_set.....	15
3.14	Demo set_di_counter_trig	15
3.15	Demo read_di_counter_trig.....	15
3.16	Demo set_power_on_value	16
3.17	Demo read_power_on_value	16
3.18	Demo set_dio_actice_states.....	16
3.19	Demo read_dio_active_states	17
3.20	Demo ao.....	17
3.21	Demo ao_readback.....	18
3.22	Demo ao_set_power_on_value	18

3.23	Demo modules_name	18
3.24	Demo multi_a0	19
3.25	Demo read_dev_set.....	19
3.26	Demo read_protocol.....	19
3.27	Demo set_watchdog.....	19
3.28	Demo set_module_add.....	20

1. M-7000 lib compile & default setting

1.1 M-7000 lib compile

Step 1: Download the Linux Modbus lib “m7k.tar.gz” from ICP DAS website to the linux system.

Step 2: Decompress the tarball “m7k.tar.gz”.


Step 3: Type ‘**cd**’ to m7k directory.

Step 4: Type ‘**make**’ or ‘**make Device=USB**’ to compile the package.
(Parameter -s means silent the command)

command ‘**make**’ use libm7k.a lib, you can use /dev/ttyS* device file to send receive Modbus protocol.

command ‘**make Device=USB**’ use libm7k_usb.a lib, you can use /dev/ttyUSB* device file to send receive Modbus protocol.

Please refer to the Figure 1-1.



```
[root@localhost ~]# tar zxf m7k.tar.gz
[root@localhost ~]# cd m7k
[root@localhost m7k]# make -s
[root@localhost m7k]#
```

Figure 1-1

1.2 M-7000 default setting

Protocol: Modbus RTU.

Module Address: 01.

DIO Type: 40.

Analog output type: Type 32, 0~10V.

Analog Input type: Type 08, -10V~10V.

Checksum disable.

Baud Rate: 9600 bps.

2. M-7000 Serial static Library Function Description

The static library is the collection of function calls of the M-7000 Series. The application structure is presented as below figure “Figure 2-1”. The user application program developed by C (C++) language can call library “libm7k.a” or “libm7k_usb.a” for M-7000 Series in user mode. And then static library will call the module command to access the hardware system.




Figure 2-1

2.1 Table of ErrorCode and ErrorString

Error code	Error ID	Error String
0	NoError	OK (No error !)
1	FunctionError	Use error function.
2	PortError	Open error port.
3	BaudRateError	Set baud rate error.
4	DataError	Set Data bits error.
5	StopError	Set Stop bits error.
6	ParityError	Set Parity bits error.
7	ChecksumError	Check sum error.
8	ComPortNotOpen	Com port not open.
10	SendCmdError	Send command error.
11	ReadComStatusError	Receive command status error.
12	ResultStrCheckError	Checksum error.
13	CmdError	Send error command.
15	TimeOut	Exceeds predetermined time and no response.
19	UnderInputRange	Under input range error.
20	ExceedInputRange	Exceed input range error.

Table 1-1

2.2 System Functions

2.2.1 Open_Com

Description:

Open specific device with device file.

Syntax:

Open_Com(char port, DWORD baudrate, char cData,
char cParity, char cStop);

Parameter:

port: Set com port number.

baudrate: Set specific baudrate. (1200~115200)

cData: Set Data bits.

cParity: Set Parity bits.

cStop: Set Stop bits.

Return:

"PortError",

"BaudRateError",

"DataError",

"ParityError",

"StopError",

"NoError".

2.2.2 modbusRequest

Description:

Send Modbus protocol request.

Syntax:

modbusRequest(char cPort, char cNetID, char cFunction, WORD
wAddr, WORD wCount, unsigned char szBuf[],
WORD wBufLen, WORD wTimeout, WORD *wT)

Parameter:

cPort: Choose com port number to send.

cNetID: Device NetID.

cFunction: Modbus RTU protocol function code.

wAddr: Address mapping.

wCount: Channel numbers

szBuf[]: Set address value and receive response.

wBufLen: szBuf[] length.

wTimeout: Set timeout.

*wt: response time(ms).

Return:

“UnderInputRange”,
“ExceedInputRange”,
“FunctionError”,
“TimeOut”,
“ReadComStatusError”,
“ResultStrCheckError”,
“CmdError”,
“NoError”.

2.2.3 Close_Com

Description:

Close specific device with device file.

Syntax:

Close_Com(char port)

Parameter:

port: Set com port number.

Return:

“FunctionError”,
“PortError”,
“NoError”.

3. M-7000 series Demo Program For Linux

All demo are work on M-7000 series device, and protocol type is Modbus RTU.

If you linked libm7k.a, and then you should use device file name is /dev/ttyS*

If you linked libm7k_usb.a, and then you should use device file name is /dev/ttyUSB*

Directory Path	File Name	Description
Include	codes.h common.h crc16.h debug.h m7000.h m7k.h modbus.h msw.h sio.h slot.h timer.h	The header of M-7000 series library.
lib	libm7k.a & libm7k_usb.a	The M-7000 series library for x86 Linux PC.
Doc	Linux_M-7000_Manual.pdf	The linux manual for M-7000 Series.
examples dir		
common	getmodbus	Send Modbus protocol to get device information.
	setmodbus	Send Modbus protocol to set value to the device.
	Modbus_utility	Get module name, NetID and baudrate.

dio	di	Read di status.
	di_counter	Read di trigger counters.
	do	Set value to single do channel.
	do_readback	Read do status.
	firmware_ver	Read firmware version.
	module_name	Read module name.
	multi_do	Set value to multiple do channels.
	read_comm_set	Get module info with baud rate and protocol.
	read_di_counter_trig	Read the digital input counter trigger edge value of a module.
	read_dio_active_stats	Read the DI/O active states of a module.
	read_power_on_value	Read the power-on value of a module.
	set_comm_set	Set module info with baud rate and protocol.
	set_di_counter_trig	Set the digital input counter trigger edge value of a module.
	set_dio_active_state	Set the DI/O active states of a module.
	set_power_on_value	Set the power-on value of a module.
	set_mod_add	Set the address of a module.
aio	ao	Set value to single ao channel.
	ao_readback	Read ao status.
	ao_set_power_on_value	Set the power-on value of a module.
	modules_name	Read module name.
	multi_ao	Set value to multiple ao channels.
	read_dev_set	Get module info with baud rate and DPS bits..
	read_protocol	Read protocol of a module.
	set_watchdog	Enable/Disable watchdog.

3.1 Demo Modbus_utility

This demo is used to detect device and show module name, NETID, baud rate. Please refer to Figure 3-1

```
[root@localhost common]# ./Modbus_utility 0
0x00 0x70 0x60 0x00
Netid is 1 Baud rate is 9600
0x00 0x70 0x24 0x00
Netid is 2 Baud rate is 9600
^C
```

Figure 3-1

3.2 Demo setmodebus

This demo is used to set value to specific address. Please refer to Figure 3-2.

```
ICPDAS M-7000 Library ver 0.0.0
function : setmodebus
Send ASCII command and wait response from a serial module
Usage: setmodebus comport baudrate netid command addr count value timeout
Example 1:setmodebus 1 115200 1 15 3 1 1 100
Write 1 with FC15 to addr 3 of netid 1 at COM1 and wait response
Example 2:setmodebus 1 115200 1 16 3 1 1234 100
Write 1234 with FC16 to addr 3 of netid 1 at COM1 and wait response
[root@localhost common]# ./setmodebus 0 9600 1 6 1 0 6000 100
```

Figure 3-2

This command is set to analog output channel 0 value 6000, and time out 100ms.

3.3 Demo getmodebus

This demo is used to get value to specific address. Please refer to Figure 3-3

```
[root@localhost common]# ./getmodebus 0 9600 1 3 1 1 100
6000
```


Figure 3-3

This command is read analog channel channel 1 value.

3.4 Demo do

Demo do is used to set single digital output channel on or off.

This demo set channel 0 on, if print “OK”, the setting is success. Please refer to Figure 3-4.




```
[root@localhost dio]# ./do
OK
```

Figure 3-4

3.5 Demo multi_do

Demo multi_do is used to set multiple digital output on or off.

This demo set channel 0 & 1 on, if print “OK”, the setting is success. Please refer to Figure 3-5.




```
[root@localhost dio]# ./multi_do
OK
```

Figure 3-5

3.6 Demo do_readback

Demo do_readback is used to read digital output channel status

This demo read digital output channel from CH0~CH3. Please refer to Figure 3-6.



```
[root@localhost dio]# ./do_readback
CH[0] 1
CH[1] 1
CH[2] 1
CH[3] 0
```

Figure 3-6

3.7 Demo di

Demo di is used to read digital input channel status.

This demo read digital input channel from CH0~CH3. Please refer to Figure 3-7

```
[root@localhost dio]# ./di
CH[0] 1
CH[1] 1
CH[2] 1
CH[3] 0
```

Figure 3-7

3.8 Demo di_counter

Demo di_counter is used to read di trigger counters.

This demo read digital input channel counters from CH0~CH3. Please refer to Figure 3-8.

```
Ch[0] DI_counter 0
Ch[1] DI_counter 0
Ch[2] DI_counter 13
Ch[3] DI counter 0
```

Figure 3-8

3.9 Demo firmware_ver

This demo is used to read firmware version. Please refer to Figure 3-9.

```
[root@localhost dio]# ./firmware_ver
0x02 0x03 0x00 0x22
```

Figuer 3-9

3.10 Demo module_name

This demo is used to read device module name. Please refer to Figure 3-10

```
[root@localhost dio]# ./module_name  
0x00 0x70 0x55 0x00
```

Figure 3-10

3.11 Demo set_mod_add

Demo set_mod_add is used to set new NETID to the dio device, NETID will be changed Immediate.

This demo is set new NETID 2 to the device, if print "OK", the setting is success. Please refer to Figure 3-11.

```
[root@localhost dio]# ./set_mod_add  
Set address result OK
```

Figure 3-11

3.12 Demo set_comm_set

Demo set_comm_set is used to set baud rate and protocol of a module, those two settings will active when re-power.

This demo is set baud rate 115200 to the device, if print "OK", the setting is success. Please refer to Figure 3-12.

```
[root@localhost dio]# ./set_comm_set  
OK
```

Figure 3-12

3.13 Demo read_comm_set

This demo is used to read baud rate and protocol. Please refer to Figure 3-13

```
[root@localhost dio]# ./read_comm_set
Baud rate: 9600
Prorocol: Modbus RTU
```

Figure 3-13

3.14 Demo set_di_counter_trig

Demo set_di_counter_trig is used to set the digital input counter trigger edge value of a module, this setting will be changed Immediate.

1 = rising edge, 0 = falling edge. For example 0x03 denotes that channels 0~1 are set as rising edge and channels 2~3 are set as falling edge.

This demo is set digital input CH0~Ch4 rising edge to the device, if print "OK", the setting is success. Please refer to Figure 3-14.

```
[root@localhost dio]# ./set_di_counter_trig
OK
```

Figure 3-14

3.15 Demo read_di_counter_trig

This demo is used to read digital input channel counter trigger edge value of a module. Please refer to Figure 3-15.

```
[root@localhost dio]# ./read_di_counter_trig
Edge setting value 0x0f
```

Figure 3-15

3.16 Demo set_power_on_value

Demo set_power_on_value is used to set the power-on value of a module.

This demo is set CH0~CH3 power on value 1, if print "OK", the setting is success. Please refer to Figure 3-16.

```
[root@localhost dio]# ./set_power_on_value
OK
```

Figure 3-16

3.17 Demo read_power_on_value

This demo is used to read power on value status of the device 0. Please refer to Figure 3-17.

```
[root@localhost dio]# ./read_power_on_value
Power on value 0x0f
```

Figure 3-17

3.18 Demo set_dio_actice_states

Demo set_dio_actice_state is used to set the DI/O active states of a module.

DI/O active states:

7	6	5	4	3	2	1	0
Reserved						OAS	IAS

Key	Description
OAS	DO active state 0: output value 1 for relay active output value 0 for relay inactive 1: output value 0 for relay active output value 1 for relay inactive
IAS	DI active state 0: input value 1 for non-signal or the low voltage; input value 0 for high voltage 1: input value 0 for non-signal or the low voltage; input value 1 for high voltage

This demo is set value 0 to the device, if print "OK", the setting is success. Please refer to Figure 3-18.

```
[root@localhost dio]# ./set_dio_actice_state  
OK
```

Figure 3-18

3.19 Demo read_dio_active_states

This demo is used to read the DI/O active states of a module. Please refer to Figure 3-19.

```
[root@localhost dio]# ./read_dio_active_stats  
DIO active states 0x00
```

Figure 3-19

3.20 Demo ao

Demo ao is used to set single analog output channel value.

This demo set value 5000 to the device, you should check type code and value range, you can refer address mapping below link.

http://www.icpdas.com/products/Remote_IO/m-7000/address_mapping/m7000_address_mapping.pdf

Please refer to Figure3-20.

```
[root@localhost aio]# ./ao  
OK
```

Figure 3-20

3.21 Demo ao_readback

Demo ao_readback is used to read analog output channel value.

This demo reads value from CH0~CH1. Please refer to Figure 3-21.

```
[root@localhost aio]# ./ao_readback
ch[0] 5000
ch[1] 0
```

Figure 3-21

3.22 Demo ao_set_power_on_value

Demo ao_set_power_on_value is used to set analog output channel power on value.

This demo sets analog output CH0 power on value 2500, if print "OK", the setting is success. Please refer to Figure 3-22.

```
[root@localhost aio]# ./ao_set_power_on_value
OK
```

Figure 3-22

3.23 Demo modules_name

This demo is used to read aio device module name. Please refer to Figure 3-23

```
[root@localhost aio]# ./modules_name
0x00 0x70 0x24 0x00
```

Figure 3-23

3.24 Demo multi_ao

Demo multi_ao is used to set multiple analog output channel value.

This demo is set 5000, 10000, 7500, to CH0 、CH1 、CH2, if print "OK", the setting is success. Please refer to Figure 3-24.

```
[root@localhost aio]# ./multi_ao
OK
```

Figure 3-24

3.25 Demo read_dev_set

This demo is used to read baud rate and data bit setting. Please refer to Figure 3-25.

```
[root@localhost aio]# ./read_dev_set
Baud rate: 9600
No parity, 1 stop bit
```

Figure 3-25

3.26 Demo read_protocol

This demo is used to read protocol type of a module. Please refer to Figure 3-26.

```
[root@localhost aio]# ./read_protocol
Modbus RTU
```

Figure 3-26

3.27 Demo set_watchdog

This demo is used to set aio device watch dog, if print "OK", the setting is success. Please refer to Figure 3-27.


```
[root@localhost aio]# ./set_watchdog
OK
```

Figure 3-27

3.28 Demo set_module_add

Demo set_module_add used to set new NETID to the aio device, NETID will be changed Immediate.

This demo is set new NETID 2 to the device, if print "OK", the setting is success. Please refer to Figure 3-28.



```
[root@localhost aio]# ./set_module_add
OK
```

Figure 3-28